

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE <b>J</b>		PAGE OF PAGES <b>1</b>   <b>2</b>	
2. AMENDMENT/MODIFICATION NO. <b>0001</b>		3. EFFECTIVE DATE <b>22 Feb 2001</b>	4. REQUISITION/PURCHASE REQ. NO. <b>SP0600-00-0404</b>		5. PROJECT NO. (If applicable) <b>DFSP San Pedro, CA</b>	
6. ISSUED BY <b>Defense Energy Supply Center</b> <b>8725 John J. Kingman Road, Suite 2941</b> <b>Ft. Belvoir, VA 22060-6222</b> <b>Bruce A.D. Jones/DESC-FPA/703-767-9334</b> <b>Email: bjones@desc.dla.mil</b> <b>Purchase Program: 6.1</b>		CODE <b>SCO600</b>	7. ADMINISTERED BY (If other than Item 6)  CODE			
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, State, and zip code)			<input checked="" type="checkbox"/> (✓)  <b>X</b>	9A. AMENDMENT OF SOLICITATION NO. <b>SP0600-01-R-0101</b>		
				9B. DATED (SEE ITEM 11) <b>Feb 15, 2001</b>		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED (SEE ITEM 13)		
CODE :		FACILITY CODE Cage Code :				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>						
<p>[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended [ ] is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following Methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted ; or (c) by separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change May be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER Specify type of modification and authority)						
E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return <u>    </u> copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)						
<p>1. The closing date for the DFSP San Pedro solicitation is hereby extended to 23 March 2001.</p> <p>2. The pre-proposal conference is scheduled for 7 March 2001 at 9 a.m. to be held at DFSP San Pedro, CA.</p> <p style="text-align: center; font-size: 1.2em;">See Page 2</p>						
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
			<b>JOAN R. TURRISI</b>			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)			(Signature of Contracting Officer)			

**3. Section C – Statement of Work is hereby changed as follows:**

a) Section C-2.2.2 Testing, change the first sentence to read:

The Contractor shall conduct all Type C testing required and test for percent Fuel system Icing Inhibitor (FSII) and Electrical Conductivity in product.

b) Section C-2.4.1.1.19 Pressure Testing:

Change the second sentence to read:

The Contractor shall ensure that the pipeline is blinded off prior to the start of the pressure testing to prevent pressurizing the entire system.